





LAKSHMIPUR PALLY BIDYUT SAMITY, PERFORMANCE TARGET AGREEMENT (FY-2022-23)

SL NO	Particular	Weight Factor		Target 2022-23	Achivement DEC- 2022
1	1.1.1. System Loss at billing Meter (w/o resale) %	LB	20	10%	9.60%
2	1.2.1 Inspection & Maintenance of Distribution line to the total energized Line including Grounding (FORM 569) %	HB	2	100	100%
3	1.3.1 Overloaded Distribution Transformer %	LB	1	0	00%
4	1.4.1 Action on Meter Report (Higher better) %	HB	1	100	100%
5	2.1.1 Accounts receivable (w/o resale & rebate) (Month)	LB	8	1.05	0.78
6	2.1.2 Reduction of over 90 days consumer (Outstanding) from last Fiscal Year (except Irrigation) %	HB	3	60	24.65%
7	2.1.3 Accounts Payable (Month)	LB	1	1	1
8	2.1.4 Collection Bill (CB) Ratio (w/o resale & rebate) %	HB	1	99	100.03%
9	2.1.5 Inter-PBS Transaction with Cross Subsidy Contribution %	HB	2	90	100%
10	2.1.6 Payment of Debt Service Liability (Crore Taka)	HB	4	20	1.39
11	2.1.7 O & M Expense per KWh (TK)	LB	2	0.85	0.83
12	2.2.1 Revenue Budget Implementation %	HB	1	95	40%
13	2.2.1 Capital Budget Implementation %	HB	1	85	21%
14	2.3.1 Operation and Data up-gradation of TMLM software %	HB	2	60	40%
15	2.3.2 GIS Mapping of 33 KV/11 KV/6.35KV Line (KM)	HB	2	478	26
16	2.3.3 Average Training hour per Employee (Hour)	HB	1	70	48.75
17	2.3.1 Ratio of Repaired Transformer to the total Repairable Transformer %	HB	2	95	100%
18	3.1.1. System Average Interruption Duration Index (SAIDI) (Minute)	LB	1	950	115.92
19	3.1.2. System Average Interruption Frequency Index (SAIFI) (Time)	LB	1	40	9.155
20	3.2.1. Power Factor at each billing point %	HB	1	0.93	0.99
21	3.3.1 Ratio of damaged & repairable Transformer to the total installed Transformer %	LB	1	1.50	3.07%
22	4.1.1. Demand note will be issued within 2 working days after receipt complete application for domestic connection (LT) %	HB	2	80	95%
23	4.1.2. Domestic connection (LT) will be ensured within 2 working days after deposit of Security money & House wiring certificate %	HB	2	75	94%
24	4.1.3. For 11 kV and above voltage level connection , Demand note will be issued after completion of field inspection within 13 working days of application subject to fulfillment of all conditions %	HB	2	75	100%
25	4.1.4. 11 kV and above voltage level connection will be provided within next 2 working days after deposit of demand note money (completion after deposit work-if applicable), installation of Solar panel, CT-PT with test report, approval of Substation installation from Office of the Chief Electric Inspector & other applicable document %	HB	2	75	100%
26	4.2.1 Public Hearing arranged by PBS-Head/Zonal Office in presence of Local Administration/Local body/ REB Officials (Number)	HB	2	20	18
27	4.2.2 Timeliness to attend Consumer's complain %	HB	2	100	100%
Total			70		

 A.G.M. (Finance) মোঃ তারা মিয়া
 A.G.M. (Admin) মোঃ ইসমাইল হোসেন মজুমদার
 DGM (Technical) Hammad Tajul Islam
 Sr. General Manager (মোঃ জাকির হোসেন)
 এজিএম (অর্থ-হিসাব) এম. এম. জি. এজিএম (প্রশাসন) এজিএম (প্রশাসন) DGM (HQ-Tech) Laxmipur PBS.
 লক্ষ্মীপুর পল্লী বিদ্যুৎ সমিতি লক্ষ্মীপুর পল্লী বিদ্যুৎ সমিতি লক্ষ্মীপুর পল্লী বিদ্যুৎ সমিতি লক্ষ্মীপুর পল্লী বিদ্যুৎ সমিতি
 লক্ষ্মীপুর পল্লী বিদ্যুৎ সমিতি লক্ষ্মীপুর পল্লী বিদ্যুৎ সমিতি লক্ষ্মীপুর পল্লী বিদ্যুৎ সমিতি লক্ষ্মীপুর পল্লী বিদ্যুৎ সমিতি