

কুমিল্লা পল্লী বিদ্যুৎ সমিতি-২

উত্তররামপুর (বিখরোড), কুমিল্লা।

কৌশলগত উদ্দেশ্য, অগ্রাধিকার, কার্যক্রম, কর্মসম্পাদন সূচক ও লক্ষ্যমাত্রাসমূহের অর্জনের ১ম ত্রৈমাসিক প্রতিবেদন (জুলাই/২০২২ হইতে সেপ্টেম্বর/২০২২ ইং পর্যন্ত)

Sl No	Description of Target Items	Unit	Weight Factor	Target for 2022-23	Achievement Up to July.-22	Achievement Up to Aug.-22	Achievement Up to Sept.-22
1	SYSTEM LOSS AT BILLING METER (w/o resale)	LB %	20	8.15	9.67	8.68	7.26
2	INSPECTION & MAINTANCE OF DISTRI. LINE AGAINST TOTAL ENERGIED LINE(KM)	HB %	2	100	25.00	32.00	67
3	REDUCING OVER LOADED DISTRIBUTION TRANSFORMER	LB %	1	0	100	100	100
4	ACTION ON METER REPORT	HB %	1	100	100	100	100
5	ACCOUNTS RECEIVABLE [MONTH](w/o GOB rebate & resale)	LB qv.Mont	8	1.00	1.03	1.01	1.01
6	REDUCTION OF OVER 90 DAYS CONSUMER (OUTSTANDING)-EXCEPT IRRIGATION.	HB %	3	60	27	48	60
7	ACCOUNTS PAYABLE	LB Month	1	1	1	1	1
8	COLLECTION BILL(CB) RATIO(w/o GOB rebate & resale)	HB %	1	99	72.07	86.58	90.92
9	INTER-PBS TRANSACTION	HB %	2	100	100	100	100
10	PAYMENT OF DEBT SERVICE [TK'000]	HB Crore Tk	4	40	0	0	0
11	O&M EXPENSES/KWH	LB Tk/Kwh	2	0.78	0.53	0.53	0.56
12	REVENUE BUDGET IMPLEMENTATION	%	1	95	8	15	24
13	CAPITAL BUDGET IMPLEMENTATION	%	1	85	1.75	2.25	4
14	OPERATION and Data Upgradation of TMLM (Software)	%	2	80	35	55	60
15	GIS Mapping of 33 KV/11KV/6.35Kv Lines	HB Km	2	600	0	30	110
16	AVERAGE TRAINING HOUR PER EMPLOYEE	HB Hour	1	70	6.57	13.54	20.30
17	RATIO OF REPAIRED TRANSFORMER TO THE TOTAL REPAIRABLE TRANSFORMER	HB %	2	95	100	100	100
18	SYSTEM AVERAGE INTERRUPTION DURATION INDEX (SAIDI)	LB Minute	1	850	23.66	41.21	104.41
19	SYSTEM AVERAGE INTERRUPTION FREQUENCY INDEX (SAIFI)	LB Times	1	39	2.21	4.47	7.25
20	POWER FACTOR AT EACH BILLING POINT	HB %	1	93	0.95	0.96	0.96
21	RATIO OF DAMAGED & REPAIRABLE TRANSFORMER AG. TOTAL INSTALLED TRANSFORMER (%)	LB %	1	1.50	0.23	0.35	0.652
22	DEMAND NOTE WILL BE ISSUED WITHIN 2 DAYS (DOMESTIC-LT)	HB %	2	80	99.45	99.52	99.68
23	DOMESTIC CONNECTION(LT) WILL BE ENSURED WITHIN 2 DAYS	HB %	2	75	85.25	85.19	85.60
24	FOR 11KV AND ABOVE VOLTAGE LEVEL CONNECTION DEMAND NOTE WILL BE ISSUED WITHIN 13 WORKING DAYS	HB %	2	75	0	1	3
25	11KV AND ABOVE VOLTAGE LEVEL CONNECTION WILL BE PROVIDED WITHIN NEXT 2 WORKING DAYS	HB %	2	75	2	2	2
26	NO. OF PUBLIC HEARING	HB NUMBER	2	20	4	10	12
27	TIMELINESS TO ATTEND CONSUMERS' COMPLAIN	HB %	2	100	100	100	100
			70				

মোঃ জসিম উদ্দিন
এজিএম (অর্থ-হিসাব)
সদস্য, এপিএ টিম
কুমিল্লা পবিস-২।

মোঃ এমায়ত হোসেন
এজিএম (প্রশাসন/এইচআর)
সদস্য, এপিএ টিম
কুমিল্লা পবিস-২।

মোঃ গোলজার আনোয়ার হোসেন চৌধুরী
এজিএম (অর্থ-রাজস্ব)
সদস্য ও সহকারী ফোকাল পয়েন্ট কর্মকর্তা
কুমিল্লা পবিস-২।

মোঃ আব্দুল আলম
ডিজিএম (কারিগরী)
সদস্য সচিব ও ফোকাল পয়েন্ট কর্মকর্তা
কুমিল্লা পবিস-২।

প্রকৌঃ মোঃ মোস্তাফিজুর রহমান
সিনিয়র জেনারেল ম্যানেজার
আহক্বায়ক, এপিএ টিম
কুমিল্লা পবিস-২।