

কুমিল্লা পল্লী বিদ্যুৎ সমিতি-২

উত্তররামপুর (বিশ্বরোড), কুমিল্লা।

কৌশলগত উদ্দেশ্য, অগ্রাধিকার, কার্যক্রম, কর্মসম্পাদন সূচক ও লক্ষ্যমাত্রাসমূহের অর্জনের তথ্য ত্রৈমাসিক প্রতিবেদন (জানুয়ারী/২০২৩ হইতে মার্চ/২০২৩ ইং পর্যন্ত)

SI No	Description of Target Items	Unit	Weight Factor	Target for 2022-23	Achievement Up to Janu. -23	Achievement Up to Feb-23	Achievement Up to Mar.-23
1	SYSTEM LOSS AT BILLING METER (w/o resale)	LB %	20	8.10	6.31	6.07	6.88
2	INSPECTION & MAINTANCE OF DISTRI. LINE AGAINST TOTAL ENERGIED LINE(KM)	HB %	2	100	85	89	95
3	REDUCING OVER LOADED DISTRIBUTION TRANSFORMER	LB %	1	0	100	100	100
4	ACTION ON METER REPORT	HB %	1	100	100	100	100
5	ACCOUNTS RECEIVABLE [MONTH](w/o GOB rebate & resale)	LB qv.Mont	8	1.00	0.68	0.78	0.82
6	REDUCTION OF OVER 90 DAYS CONSUMER (OUTSTANDING)-EXCEPT IRRIGATION.	HB %	3	60	83	86	91
7	ACCOUNTS PAYABLE	LB Month	1	1	1	1	1
8	COLLECTION BILL(CB) RATIO(w/o GOB rebate & resale)	HB %	1	99	99.32	97.79	97.95
9	INTER-PBS TRANSACTION	HB %	2	100	100	100	100
10	PAYMENT OF DEBT SERVICE [TK'000]	HB Crore Tk	4	40	6.47	6.47	8.60
11	O&M EXPENSES/KWH	LB Tk/Kwh	2	0.78	0.76	0.77	0.79
12	REVENUE BUDGET IMPLEMENTATION	%	1	95	48	57	66
13	CAPITAL BUDGET IMPLEMENTATION	%	1	85	18	25	31
14	OPERATION and Data Upgradation of TMLM (Software)	%	2	80	81	81	85
15	GIS Mapping of 33 KV/11KV/6.35Kv Lines	HB Km	2	600	543	465	475
16	AVERAGE TRAINING HOUR PER EMPLOYEE	HB Hour	1	70	53	60	67
17	RATIO OF REPAIRED TRANSFORMER TO THE TOTAL REPAIRABLE TRANSFORMER	HB %	2	95	100	100	100
18	SYSTEM AVERAGE INTERRUPTION DURATION INDEX (SAIDI)	LB Minute	1	850	269.04	286.59	339.04
19	SYSTEM AVERAGE INTERRUPTION FREQUENCY INDEX (SAIFI)	LB Times	1	39	20.35	22.61	24.86
20	POWER FACTOR AT EACH BILLING POINT	HB %	1	93	0.97	0.97	0.97
21	RATIO OF DAMAGED & REPAIRABLE TRANSFORMER AG. TOTAL INSTALLED TRANSFORMER (%)	LB %	1	1.50	1.39	1.40	1.45
22	DEMAND NOTE WILL BE ISSUED WITHIN 2 DAYS (DOMESTIC-LT)	HB %	2	80	99.18	99.27	99.36
23	DOMESTIC CONNECTION(LT) WILL BE ENSURED WITHIN 2 DAYS	HB %	2	75	86.39	86.68	86.97
24	FOR 11KV AND ABOVE VOLTAGE LEVEL CONNECTION DEMAND NOTE WILL BE ISSUED WITHIN 13 WORKING DAYS	HB %	2	75	100	100	100
25	11KV AND ABOVE VOLTAGE LEVEL CONNECTION WILL BE PROVIDED WITHIN NEXT 2 WORKING DAYS	HB %	2	75	100	100	100
26	NO. OF PUBLIC HEARING	HB NUMBER	2	20	25	27	29
27	TIMELINESS TO ATTEND CONSUMERS' COMPLAIN	HB %	2	100	100	100	100

70

15.04.23  
মোঃ জসিম উদ্দিন  
এজিএম (অর্থ-হিসাব)  
সদস্য, এপিএ টিম  
কুমিল্লা পবিস-২।

15.04.23  
মোঃ এম্মোত হোসেন  
এজিএম (প্রশাসন/এইচআর)  
সদস্য, এপিএ টিম  
কুমিল্লা পবিস-২।

15/04/23  
মোঃ পোলজার আনোয়ার হোসেন চৌধুরী  
এজিএম (অর্থ-রাজস্ব)  
সদস্য ও সহকারী ফোকাল পয়েন্ট কর্মকর্তা  
কুমিল্লা পবিস-২।

15/04/23  
মোঃ মাসুদুল আলম  
ডিজিএম (কারিগরী)  
সদস্য সচিব ও ফোকাল পয়েন্ট কর্মকর্তা  
কুমিল্লা পবিস-২।

15/04/23  
প্রকৌঃ মোঃ মোস্তাফিজুর রহমান  
সিনিয়র জেনারেল ম্যানেজার  
আইসিআই, এপিএ টিম  
কুমিল্লা পবিস-২।